



**SCHEDULE OF HEATING COILS**  
 BASED ON 200 °F W.T.

MARK	CFM	S.P.	HEATING CAPACITY	WATER PRESSURE DROP	MAX. WATER VELOCITY	FACE VELOCITY	AIR PRESSURE DROP	COIL TYPE	ROWS	FINS	COIL AREA
HC-1	1000	64	180	10	3.0	1.7	0.50	PERMA ELCO	1	50	11224

**FAN SCHEDULE**

NO.	CFM	S.P.	T.S.	HEATING CAPACITY	WATER PRESSURE DROP	MAX. WATER VELOCITY	FACE VELOCITY	AIR PRESSURE DROP	COIL TYPE	ROWS	FINS	COIL AREA
F-1	1915	16.5	—	—	—	—	—	—	—	—	—	—
F-2	80	—	—	—	—	—	—	—	—	—	—	—
F-3	80	—	—	—	—	—	—	—	—	—	—	—

**ELECTRIC UNIT HEATER SCHEDULE**

NO.	BTU/HR	WATTS	VOLTS	PHI	MODEL	MANUFACTURER	REMARKS
CUH-1	5100	1500	120	1	CAH-1E1	CHRYSLER	ENT. LOBBY
CUH-2	5100	1500	120	1	CAH-1E1	CHRYSLER	STAIR 2
CUH-3	2500	750	120	1	CAH-1E1	CHRYSLER	MCH.
CUH-4	2500	750	120	1	CAH-1E1	CHRYSLER	JAN.
CUH-5	11	150	120	1	CAH-1E1	CHRYSLER	ELEV. MACH. RM.



These construction documents are for use in connection with the project described herein. They are to be used only with the contract documents, specifications, and drawings. No part of these documents shall be reproduced or transmitted in any form or by any means, electronic, mechanical, photocopying, recording, or by any information storage and retrieval system, without the prior written permission of the Architect/Engineer. The use of these documents and drawings is limited to the project and location specified herein. No other use or reproduction is permitted.